



September 6, 2018

Mr. JEFFREY WEST
Allied Industries International Inc.
3013 BANK Street
CHARLOTTE, NC 28203

Dear Mr. West:

On behalf of the National Floor Safety Institute, I would like to thank you for submitting your product for Phase 1 testing. The product listed below was tested per the ANSI/NFSI B101.1-2009 Test Method for Measuring Wet SCOF of Common Hard-Surface Floor Materials and the ANSI/NFSI B101.3-2012 Test Method for Measuring Wet DCOF of Common Hard-Surface Floor Materials on September 6, 2018.

Product	Average SCOF	Pass/Fail	Average DCOF	Pass/Fail
Eco-Grip	0.62	Pass	0.43	Pass

The product meets our minimum acceptable wet SCOF value of 0.60 and our minimum wet DCOF value of 0.42, therefore the product is eligible for Phase 2 testing. Again, thank you for submitting your product to the NFSI.

Sincerely,

Russell J. Kendzior
President